



Gas Safety Record

Gas Safe Register is a registered trademark of the HSE and is used under licence



This Gas Safety Record was completed on 11 Sep 2018 by Steve Gardner , 4263422.

Serial No: 000526

Number of appliances: 1


Your next Gas Safety Check is due on 11 Sep 2019

Registered Business SG Heating & Plumbing Address: 156 Estcourt road , Gloucester , Gloucestershire Postcode: GL1 3BE Phone: 07891751633	Gas Safe No: 214580	Job Address Name: Mr James Hunt Address: 88 Devon Avenue Cheltenham Postcode: GL518BT Phone:	Client Details Client Name: Address: Postcode: Phone:
---	----------------------------	---	--

Location	Appliance type	Make	Model	Landlord's appliance	Appliance inspected	Appliance serviced	Appliance safe to use
1 Kitchen	Condensing Boiler	Worcester	30i Erp combi	Yes	Yes	Yes	Yes
2							
3							
4							
5							

	Operating pressure (Mbar)	Heat input (kW/h or btu/h)	Initial combustion analyser reading	Final combustion analyser reading	Safety device correct operation	Ventilation provision satisfactory	Visual condition of chimney/ termination satisfactory	Flue type	Spillage test	Smoke pellet flue flow test	Flue visual condition	Flue performance checks	Approved CO alarm fitted	Is CO alarm in date	Testing of CO alarm satisfactory
1	18.7 Mbar	28.93 kW/h	0.0006	0.0006	Yes	Yes	Yes	RS	n/a	n/a	Pass	n/a	No	n/a	n/a
2															
3															
4															
5															

Defects	Actions taken	Warning Notice
1 _____	_____	_____
2		
3		
4		
5		

Gas Installation	Issued by	Received by
Gas Installation pipework visual inspection satisfactory		
Emergency control valve (ecv) accessible		
Satisfactory gas tightness test		
Protective equipotential bonding satisfactory		
Gas Installation Notes: _____		
Gas Installation Warning Notice Completed	Gas operative: Steve Gardner 11 Sep 2018 Gas Safe ID No: 4263422	11 Sep 2018 Gas User/Client Not Present
Electrical Cross Bonding Notice Completed		