



# Gas Safety Record

Gas Safe Register is a registered trademark of the HSE and is used under licence



This Gas Safety Record was completed on 11 Sep 2018 by Steve Gardner , 4263422.

Serial No: 000527

Number of appliances: 1


Your next Gas Safety Check is due on 11 Sep 2019

<b>Registered Business</b> SG Heating & Plumbing Address: 156 Estcourt road , Gloucester , Gloucestershire Postcode: GL1 3BE Phone: 07891751633	<b>Gas Safe No:</b> 214580	<b>Job Address</b> Name: Mr James Hunt Address: 94 Devon Avenue Cheltenham GL518BT Postcode: Phone:	<b>Client Details</b> Client Name: Address: Postcode: Phone:
---	----------------------------	---	--

Location	Appliance type	Make	Model	Landlord's appliance	Appliance inspected	Appliance serviced	Appliance safe to use
1 Kitchen	Condensing Boiler	Worcester	24i system boiler	Yes	Yes	Yes	Yes
2							
3							
4							
5							

	Operating pressure (Mbar)	Heat input (kW/h or btu/h)	Initial combustion analyser reading	Final combustion analyser reading	Safety device correct operation	Ventilation provision satisfactory	Visual condition of chimney/ termination satisfactory	Flue type	Spillage test	Smoke pellet flue flow test	Flue visual condition	Flue performance checks	Approved CO alarm fitted	Is CO alarm in date	Testing of CO alarm satisfactory
1	18.7 Mbar	22.97 kW/h	0.0005	0.0005	Yes	Yes	Yes	RS	n/a	n/a	Pass	n/a	No	n/a	n/a
2															
3															
4															
5															

Defects	Actions taken	Warning Notice
1 _____	_____	_____
2		
3		
4		
5		

<b>Gas Installation</b> Gas Installation pipework visual inspection satisfactory Yes Emergency control valve (ecv) accessible Yes Satisfactory gas tightness test Yes Protective equipotential bonding satisfactory Yes Gas Installation Notes: _____ Gas Installation Warning Notice Completed N/A Electrical Cross Bonding Notice Completed N/A	<b>Issued by</b>  Gas operative: Steve Gardner 11 Sep 2018 Gas Safe ID No: 4263422	<b>Received by</b>  11 Sep 2018 <b>Gas User/Client Not Present</b>
--	---	---