



Gas Safety Record

Gas Safe Register is a registered trademark of the HSE and is used under licence



This Gas Safety Record was completed on 11 Sep 2018 by Steve Gardner , 4263422.

Serial No: 000529

Number of appliances: 1

Your next Gas Safety Check is due on 11 Sep 2019

Registered Business SG Heating & Plumbing Address: 156 Estcourt road , Gloucester , Gloucestershire Postcode: GL1 3BE Phone: 07891751633	Gas Safe No: 214580	Job Address Name: Mr James Hunt Address: 6a Cornwall Avenue Cheltenham Attic Postcode: Phone:	Client Details Client Name: Address: Postcode: Phone:
--	---------------------	---	---

Location	Appliance type	Make	Model	Landlord's appliance	Appliance inspected	Appliance serviced	Appliance safe to use
1 Bedroom	Boiler	Worcester	24i junior	Yes	Yes	Yes	Yes
2							
3							
4							
5							

Operating pressure (Mbar)	Heat input (kW/h or btu/h)	Initial combustion analyser reading	Final combustion analyser reading	Safety device correct operation	Ventilation provision satisfactory	Visual condition of chimney/ termination satisfactory	Flue type	Spillage test	Smoke pellet flue flow test	Flue visual condition	Flue performance checks	Approved CO alarm fitted	Is CO alarm in date	Testing of CO alarm satisfactory
1 13.9 Mbar	23.89	n/a	n/a	Yes	Yes	Yes	RS	n/a	n/a	Pass	n/a	No	n/a	n/a
2														
3														
4														
5														

Defects	Actions taken	Warning Notice
1 Boiler connected through a plug point not a fused spur. 15mm gas pipe connected to boiler should be replaced with a fused spur.	Cables should be replaced with a fused spur. Boiler operating correctly.	_____
2		
3		
4		
5		

Gas Installation	
Gas Installation pipework visual inspection satisfactory	No
Emergency control valve (ecv) accessible	Yes
Satisfactory gas tightness test	Yes
Protective equipotential bonding satisfactory	Yes
Gas Installation Notes: Recommend carbon monoxide alarm is installed.	
Gas Installation Warning Notice Completed	000529 01
Electrical Cross Bonding Notice Completed	N/A

Issued by

Gas operative: Steve Gardner
11 Sep 2018
Gas Safe ID No: 4263422

Received by

11 Sep 2018
Gas User/Client Not Present



Gas Warning Notice

Danger Do Not Use

Gas Safe Register is a registered trademark of the HSE and is used under licence



Warning Notice Reference No: 000529 01 This WARNING NOTICE was completed on 11 Sep 2018 by Steve Gardner , 4263422.

This form should be completed in accordance with the requirements of the current Gas Safe Industry Unsafe Situations Procedure
It is strongly advised the recommended action is taken immediately to avoid danger to life or property. Failure to do so may breach the law.

Registered Business SG Heating & Plumbing Address: 156 Estcourt road , Gloucester , Gloucestershire Postcode: GL1 3BE Phone: 07891751633	Gas Safe No: 214580	Job Address Name: Mr James Hunt Address: 6a Cornwall Avenue Cheltenham Attic Postcode: Phone:	Client Details Client Name: Address: Postcode: Phone:
---	----------------------------	--	--

	Location	Appliance type	Make	Model	Serial No.
The Gas Installation	n/a	n/a	n/a	n/a	n/a

Gas Escape	A gas escape has been detected on the installation and the supply turned off and disconnected:	Yes No n/a
-------------------	--	----------------------------------

The Installation is AT RISK (AR) because:

- A warning label has been attached No
- With the clients permission the installation has been turned off No

PLEASE NOTE: One or more faults exist on the installation. If operated it may in the future constitute a danger to life or property and should not be used. It is strongly recommended work is carried out to rectify the situation.

I confirm that the situation recorded above has been identified and brought to the attention of the Gas User or Client in accordance With the Gas Safety (Installation and Use) Regulations, Industry Standards and Procedures.

Gas operative: Steve Gardner
11 Sep 2018
Gas Safe ID No: 4263422

I confirm I have received this Warning Notice regarding the safety of the gas installation. I understand that use of the installation in the case of an IMMEDIATELY DANGEROUS or AT RISK installation, could present a hazard and could place me in breach of the Gas Safety (Installation and Use) Regulations

11 Sep 2018

Where appropriate an IMMEDIATELY DANGEROUS or AT RISK installation has been made safe and this notice sent to the client